Below is a data table of compiled data referencing the approved maximum recommended levels for several chemical factors.

NOTE: mg/ L is the same as ppm

	Maximum Recommended Level:
Alkalinity	20- 200 mg/L
Ammonia	1.5 mg/L
Chloride	250 mg/L
Chlorine	4 mg/L (optimal range is 0.2-0.5 mg/L)
Chromium	0.1 mg/L
Copper	2 mg/L
Dissolved Oxygen	6-9 mg/L (recommended minimum)
Hardness	60-120 mg/L
Iron	0.3 mg/L
Nitrate	10 mg/L
pH	6.5-8.5
Phosphate	0.1 mg/L
Turbidity	1 NTU
Coliform bacteria	0 CFU/ 100 mL